



**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT  
NO OBJECTION CERTIFICATE**



From  
The Director General  
State Disaster Response and Fire Services,  
Telangana, Hyderabad.

To  
• P.Srinivas Reddy,  
Bhavishya School, in Sy.No. 58/1/F,  
Hastinapuram, Saroomagar(M), RR. Dist.

Rc No. **286540002019** Dated: **02/03/2020**

Sir,  
Sub:

TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT-

Issue of No Objection Certificate for Occupancy to the Non Multi storeyed Building of **BHAVISHYA SCHOOL, IN SY.NO. 58/1/F, SITUATED AT DEVAKAMMATHOTA, HASTINAPURAM, SAROORNAGAR MANDAL, RANGAREDDY DIST./ Hastinapuram/Saroomagar / Rangareddy - Regarding**



Ref:

1. Acknowledgment No **286540002019** dt.**02/03/2020**
2. This Office Provisional NOC Rc No., dt.
3. Inspection Committee Report, Ack No. **286540002019**, dt.**02/03/2020**

\*\*\*\*\*

1. The Multi Storeyed Building Inspection committee, vide reference (3) have inspected the Non Multi Storeyed Building of **BHAVISHYA SCHOOL, IN SY.NO. 58/1/F, SITUATED AT DEVAKAMMATHOTA, HASTINAPURAM, SAROORNAGAR MANDAL, RANGAREDDY DIST./ Hastinapuram/Saroomagar / Rangareddy** and submitted the following report.

2. The builder was issued Provisional No Objection certificate vide reference cited(2) for construction of Non Multi Storeyed Building **Ground 4 Floors**, with for Occupancy ( ). Now the builder has constructed Non Multi Storeyed Building with **Ground 4 Floors**, with a height of **1996.35 Meters** for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy ( ) and requested for No Objection Certificate for Occupancy.

3. Open Space : The builder provided the following open spaces all around the building

Sl.No	Side	Open space Required as per Provisional No Objection Certificate	Open space Provided
1	FRONT	6.00	7.00
2	REAR	6.00	6.50
3	Side-1	6.00	6.70
4	Side-2	6.00	7.00
5	Front Direction East		

4. Means of Access :

Sl.No.	Gate Width As per NBC 2016	Required	Provided
1	Entry Gate width	6.00	6.60
2	Exit Gate Width	6.00	6.90
3	Entry Gate Hand Clearance	4.50	5.00
4	Exit Gate Hand Clearance	4.50	5.00

5. Travel Distance

Sl.No	Item / Description	Required (Not More than in Mtrs.)	Provided
1	Farthest point(Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	22.00
2	The Dead end of the corridor length in exit access.(6 mtrs for Educational, Institutional and Assembly, 15 mtrs for other Occupancies)	6.00	6.00

6. Stair Cases (As per NBC 2016)

Sl.No.	Type of staircases	Width (In Mtrs)	No of staircases	Floors from	Floors to
--------	--------------------	-----------------	------------------	-------------	-----------

Respondent  
**BHAVISHYA SCHOOL**  
Devakamma Thota,  
Hastinapuram, R.R. Dist.

*J. Srinivas Reddy*  
PRINCIPAL  
Bhavishya School  
Z.P.Road, Devakamma Thota, Hastinapuram,  
R.R. Dist, Hyderabad. T.S. Pin: 500079.